

# Detailed Latest Test Results



# SEAWARD

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2013 To: 14/04/2013

Site: KSA		Location: Van		
Asset ID: KSA 005	Description: 110V TRANSFORMER	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.05	Ohm	Pass
Earth	13/04/2013	0.05	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA002	Description: LEAD 110V	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.19	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA003	Description: LEAD	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.18	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA004	Description: GRINDER	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA006	Description: LAMP 110V	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.12	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA007	Description: 4 WAY REEL	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.26	Ohm	Pass
Earth	13/04/2013	0.26	Ohm	Pass
Earth	13/04/2013	0.26	Ohm	Pass
Earth	13/04/2013	0.26	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Polarity	13/04/2013			Pass
Overall: Pass				
Asset ID: KSA008	Description: SAW	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA010	Description: 9 INCH GRINDER	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				
Asset ID: KSA011	Description: ROTABROACH	User: MIKE	Test Instrument: 25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.07	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

# Detailed Latest Test Results



# SEAWARD

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2013 To: 14/04/2013

Overall: Pass

Asset ID:	Description:	User:	Test Instrument:	
KSA012	DRILL	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA013	WELDER	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.05	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA014	WHIP END POWER	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA015	HOIST	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.05	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA017	HILTI DRILL	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA018	CHOP SAW	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA019	SAW	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA021	NUTRUNNER	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA022	SAW	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA030	LEAD 14M	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.19	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass
Overall: Pass				

Asset ID:	Description:	User:	Test Instrument:	
KSA032	LEAD	MIKE	25C-0254	
Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information

# Detailed Latest Test Results



# SEAWARD

Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 01/02/2013 To: 14/04/2013

Earth	13/04/2013	0.19	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Asset ID: KSA033	Description: 3WAY ADAPTER	User: MIKE	Test Instrument: 25C-0254
------------------	---------------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass

Overall: Pass

Asset ID: KSA034	Description: HOOVER	User: MIKE	Test Instrument: 25C-0254
------------------	---------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Asset ID: KSA035	Description: SOLDERING IRON 30W	User: MIKE	Test Instrument: 25C-0254
------------------	---------------------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.07	Ohm	Pass
Insulation	13/04/2013	17.51	MOhm	Pass

Overall: Pass

Asset ID: KSA036	Description: SANDER	User: MIKE	Test Instrument: 25C-0254
------------------	---------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Asset ID: KSA037	Description: 110V EXT LEAD 10M	User: MIKE	Test Instrument: 25C-0254
------------------	--------------------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Earth Current	13/04/2013	25	A	Information
Earth	13/04/2013	0.2	Ohm	Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Asset ID: KSA039	Description: DREMEL	User: MIKE	Test Instrument: 25C-0254
------------------	---------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Asset ID: KSA20	Description: 18V DRILL	User: MIKE	Test Instrument: 25C-0254
-----------------	------------------------	------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual	13/04/2013			Pass
Insulation	13/04/2013	>99.99	MOhm	Pass

Overall: Pass

Total Tests: 27